



## Product certificate K97837-2

Issued 2025-04-01

Replaces K97837/01

Page 1 of 2

### Wide range couplings

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### Crane BS&U - (Water)

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline

BRL-K775: "Ductile iron fittings for pipes of ductile iron, grey cast iron, steel, PVC-U, PE or fibre-reinforced cement for the transport of drinking water": dated 2018-12-01,

which covers the requirements of

EN-14525:2004 "Ductile iron wide tolerance couplings and flange adaptors for use with pipes of different materials: ductile iron, Grey iron, Steel, PVC-U PE, Fibre-cement to convey potable water".

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.com](http://www.kiwa.com) in order to ensure that this certificate is still valid.*

# CERTIFICATE

287180711

**Kiwa Nederland B.V.**  
Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
NL.Kiwa.info@Kiwa.com  
[www.kiwa.com](http://www.kiwa.com)

Company	Manufacturing site
Crane BS&U - (Water)	Viking Johnson
Crane House,	46-48 Wilbury Way
Epsilon Terrace, West Road	SG4 0UD Hitchin, Hertfordshire
IP3 9FJ IPSWICH, SUFFOLK	United Kingdom of Great Britain
United Kingdom of Great Britain and Northern Ireland	
Northern Ireland	+44 (0)1462 443311
Tel. +44 (0)7831-609615	info@vikingjohnson.com
info@vikingjohnson.com	
<a href="http://www.vikingjohnson.com">www.vikingjohnson.com</a>	



**Certification process  
consists of initial and  
regular assessment of:**

- quality system
- product

## Wide range couplings

---

### PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate

#### Ultra grip, restrained

##### PN 16

DN 40, DN 50, DN 65, DN 80, DN 100, DN 125, DN 150, DN175, DN 200, DN 250, DN 300,

##### PN 10

DN 350, DN 400, DN 450, DN 500, DN 600

### Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

### MARKING

The Kiwa®-mark products are marked with the word mark "KIWA ". \*

Place of the mark: on the outside of the coupling.

\*) for small fittings marking with only KK is permitted

Compulsory specifications:

- Manufacturer's name or mark;
- Identification of the year of manufacture;
- Identification of ductile iron;
- DN and PN rating of flanges when applicable;
- Reference to the standard EN 14525;
- An identification of the minimum maximum outside diameters (range of external diameters over which the products works);
- PFA of the coupling of the flange adaptor.

Method of marking:

- Non-erasable;
- visible after assembly.

### APPLICATION AND USE

The products referred to in this evaluation guideline are intended for use in pipe systems for drinking water transport.

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Crane BS&U - (Water)
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.